




ANSI/UL1479 (ASTM E814)	CAN/ULC S115
F Rating - 3 Hr	F Rating - 3 Hr
T Rating - 0 Hr	FT Rating - 0 Hr
L Rating At Ambient - Less Than 1 CFM/sq ft	FH Rating - 3 Hr
L Rating At 400 F - Less Than 1 CFM/sq ft	FTH Rating - 0 Hr
	L Rating At Ambient - Less Than 1 CFM/sq ft
	L Rating At 400 F - Less Than 1 CFM/sq ft



Section A-A

- Floor or Wall Assembly** - Lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) concrete floor or wall. Min thickness of concrete is shown in table in Item 4B. Floor may also be constructed of any min 6 in. (152 mm) thick hollow-core **Precast Concrete Units***. Wall may also be constructed of any UL Classified **Concrete Blocks***. Max diam of opening is 14 in. (356 mm). Max diam of opening in floors constructed of hollow-core is 7 in. (178 mm). See **Concrete Blocks (CAZT)** or **Precast Concrete Units (CFTV)** categories in the Fire Resistance Directory for names of manufacturers.
- Steel Sleeve** - (Optional) - Nom 14 in. (356 mm) diam (or smaller) Schedule 10 (or heavier) steel pipe or No. 26 ga (0.022 in. or 0.56 mm thick) sheet steel sleeve with square anchor flange spot welded to the sleeve at approx mid-height. Sleeve cast or grouted in place flush with floor or wall surfaces. Steel pipe sleeve may project a max of 2 in. (51 mm) beyond the floor or wall surfaces.
- Through Penetrant** - One metallic pipe, conduit or tube to be installed eccentrically or concentrically within the firestop system. The annular space between the pipe, conduit or tube and the periphery of the opening shall be min 0 in. (point contact). The max annular space is 1 in. or 2 in. (25 or 51 mm) as shown in the table in Item 4B. Pipe, conduit or tube to be rigidly supported on both sides of the floor or wall assembly. The following types and sizes of metallic pipes, conduits and tubes may be used:
 - Steel Pipe** - Nom 12 in. (305 mm) diam (or smaller) Schedule 5 (or heavier) steel pipe.
 - Iron Pipe** - Nom 12 in. (305 mm) diam (or smaller) cast or ductile iron pipe.
 - Conduit** - Nom 6 in. (152 mm) diam (or smaller) rigid steel conduit, nom 4 in. (102 mm) diam (or smaller) steel electrical metallic tubing (EMT) or nom 4 in. (102 mm) diam (or smaller) flexible steel conduit.
 - Copper Pipe** - Nom 4 in. (102 mm) diam (or smaller) Regular (or heavier) copper pipe.
 - Copper Tube** - Nom 4 in. (102 mm) diam (or smaller) Regular L (or heavier) copper tube.



Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876

Reproduced courtesy of Underwriters Laboratories, Inc.
Created or Revised: January 23, 2014

Distribuidor oficial en Chile: SAFE ENERGY SPA www.safe-energy.cl contacto@safe-energy.cl +562 26216006



3A. **Through Penetrating Product* - Flexible Metal Piping** - As an alternate to Item 3, one nom 2 in. (51 mm) diam (or smaller) flexible steel pipe (with or without plastic jacketing) to be installed either concentrically or eccentrically within the firestop system. The annular space between the pipe, conduit or tube and the periphery of the opening shall be min 0 in. (0 mm or point contact). The max annular space is 1 or 2 in. (25 or 51 mm) as shown in the table in Item 4B. Pipe to be rigidly supported on both sides of the floor or wall assembly.

OMEGA FLEX INC

GASTITE, DIV OF TITEFLEX

WARD MFG L L C

4. **Firestop System** - The firestop system shall consist of the following:

A. **Packing Material** - When required as shown in the table in Item 4B, min 4 pcf (64 kg/m³) mineral wool batt insulation compressed and tightly packed to min 2-1/4 in. (57 mm) thickness. Packing material recessed from top surface of floor or both surfaces of wall as required to accommodate fill material (Item 4B). When packing material is shown as being optional, mineral wool or glass fiber insulation or polyethylene foam backer rod may be used as a permanent form to facilitate installation of the fill material. In floors constructed of hollow-core precast concrete units, packing material to be recessed from both top and bottom surfaces of floor, as required to accommodate fill material (Item 4B). When steel sleeve projects from top of floor or from both sides of wall, the thickness of mineral wool batt packing material should be increased by an amount equal to the distance that the sleeve extends past the floor or wall surface.

B. **Fill, Void or Cavity Material* - Sealant** - Fill material applied within annulus, flush with top surface of floor assembly or top edge of steel sleeve. In walls and in floors constructed from hollow core precast concrete units, fill material applied symmetrically on both sides of assembly flush with wall/floor surfaces or both ends of steel sleeve. At point contact location, apply min 1/4 in. (6 mm) diam bead of fill material at pipe/concrete interface or pipe/steel sleeve interface on top surface of floor or both surfaces of wall or precast concrete units. The fill material thickness shall be as specified in the following table:

Min Concrete Thickness in. (mm)	Steel Sleeve	Max Annular Space, in. (mm)	Packing Material	Min Fill Material Thickness in. (mm)	F Rating
2-1/2 (64)	Optional	2 (51)	Required	1/4 (6)	3 hr
4-1/2 (114)	Optional	1 (25)	Optional	1/2 (13)	2 hr

SPECIFIED TECHNOLOGIES INC - SpecSeal LCI Sealant

* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.



Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876

Reproduced courtesy of Underwriters Laboratories, Inc.
Created or Revised: January 23, 2014

(800)992-1180 • (908)526-8000 • FAX (908)231-8415 • E-Mail:techserv@stifirestop.com • Website:www.stifirestop.com



C-AJ-1353
PAGE 2 OF 2